

Water Quality Noncompliance Notification

See back of Form for Guidance for Completion

Unauthorized Discharge

Reportable Effluent Violation

Other

General Information

Entity Name: Trophy Club Municipal Utility District No. 1

Telephone No (#####): (682) 813-4600

Permittee

TCEQ Region: R4 - DFW

County: Denton

*Permit Number: TX0055735

Subscriber

Noncompliance Summary

Description and Cause of Noncompliance (include location, discharge route, and estimated volume of unauthorized discharge):

On Feb. 15, 2021 we had a SSO at a manhole located at the corner of Sheldon and Abbott dr. This was due to a widespread power outage in the area causing our lift stations to quit working. We estimated 100 gallons overflowed. Power was restored at 5:20 and the water receded in the manhole. We cleaned up and sprayed the affected area with water and clear mint.

Duration:

Start Date: 2/15/21

End Date: 2/15/21

Or

Date Expected to be Corrected: 2/15/2021

Time: 5:15pm

Time: 6:00pm

Potential Danger to Human Health and Safety or the Environment:

None

Actions Taken

Monitoring Data: Data should be attached or submitted to TCEQ when available.

Field Measurements

Laboratory Samples

Fish Kill (If yes, estimated number killed):

Yes No

Yes No

Yes No

Actions Taken to Mitigate Adverse Effects:

Cleaned, sprayed and disinfected affected area.

Actions Taken to Correct the Problem and Prevent Recurrence:

We have the portable generator on stand by and will be monitoring all lift stations 24 hours a day until power is restored completely.

Verification Information

Information Reported By (Name/Title): Frank Isola\ Supervisor.

Date Reported: 2/16/2021

Signature:



Note: If this form is being used for a 5-day written report, a copy of the form should be sent to the TCEQ Region Office, and the original to: TCEQ, Compliance Monitoring Team (MC224), Enforcement Division, P.O. Box 13087, Austin, TX 78711-3087.

* If the noncompliance is an unauthorized discharge from a wastewater collection system, use the permit number of the treatment plant to which the collection system is tied. If you are uncertain of this permit number, you may call the TCEQ Regional Office for assistance.